Highways Annex A - dated 01 November 2025.

Issue	Date Reported	By Whom	То	Progress
Parish Steward Visits 2023 Usually, on a Thursday in month.	Next Visits 2024			Any issues to be reported to KW for Parish Steward's next visit.
	26 Feb			
	26 Mar			
West Tockenham, Flooding. C120 Main Village	Aprl 23	DK	wc	Blocking gully investigations at Field view indicates a link to main Village flooding issues. Work carried out 21st Nov 24 however main Village flooded after this during 'Storm Bert' Nov 24.
Tockenham Wick, Flooding Update from site visit 9 th Oct 2024 with David Arnup (DA) and Martin Cook (MC). 21 st Nov Chase email to MC – Reply, MC chasing Drainage Team for meeting.	April 23	KW	WC	KW had a further site meeting with DA and MC 9 th Oct 2024. Investigations to proceed looking at alternative measures to reduce flood risk. Action DA and MC.
Request for deterrent to avoid domestic fence damage from large vehicles mounting kerb at corner of Orchard Lane/C130 Junction Update 9 th Oct 2024 from David Arnup	May 23	KW	WC	Deterrent - due installation 2024 Case closed - Work completed.
Opposite Field View - No 1 Tockenham. Blocked drain/gully. Road area by sewage plant now breaking up due to constant flow of water. Issue linked to main Village flooding. SEE ABOVE	Sept 23	KW	WC	Case No.00125935. Investigation Aug 24 shows fractured pipe. Works due Oct 24. Works carried out 21st Nov 24.
Flooding – south of Rowley Copse.	Nov 23	KW	WC	Culvert blasted. Awaiting watercourse re-direction work by landowner east side of culvert. NOTE – Concerns exist that this may impact on Tockenham Corner.
Junction with Preston Lane C130. – Mermaid Corner. Continuous flooding. Update – Nov 24 KW chase email to MC/DA to hasten works request.	Nov 23	KW	WC	Case number is 0013210. Requires extensive surveys. Following site meeting with KW and AB, drainage and highways teams to work together to investigate.
Pothole case No Greenway 148264 Orchard Lane – 148105 and 148101 Greenway 144238.	Jan 24	KW	My Wilts App	Reported. Awaiting repair/investigation. Ongoing as C class road – low priority.
Progressive surface damage to C130 Orchard Lane. DA site visit identified that ditch east side of C130 no longer exists and should be re-inserted by Queens Court landowner.	March 24	KW	WC	Report and recommendation received from DA 12 Jul 24 that ditch be re-inserted after end of Aug 24 nesting season.